NOTES:

1. MINIMUM AISLE CLEARANCE 36" FROM BOILER SIDES AND REAR. (THIS REQUIREMENT MAY VARY WITH LOCATION. CHECK STATE AND LOCAL CODES IN THE AREA OF INSTALLATION.)
2. OPTIONS AND ADDITIONAL EQUIPMENT ORDERED MAY AFFECT OVERALL DIMENSIONS. DRAWINGS ARE FOR STANDARD BOILER PACKAGE.



DOOR SWING AND AISLE CLEARANCE





REFERENCE DRAWINGS

BLWR HOUSING:	#235A0126-04
PLENUM:	#212B0158
PV:	#101B0923
PV BASE:	#201B0235
FR FLUE BOX:	#205B0134
RR FLUE BOX:	#206B0152

THIS DRAWING IS THE PROPERTY OF THE JOHNSTON BOILER COMPANY. THE DISCLOSURES CONTAINED ON THIS DRAWING ARE MADE WITH THE UNDERSTANDING THAT THEY ARE CONFIDENTIAL AND WILL NOT BE USED IN ANY WAY DETRIMENTAL TO THIS COMPANY'S INTEREST.

JOHNSTON BOILER COMPANY

REVISIONS		
A	3-19-10	CW
REVD LOCATION OF AUX. CONNECTION AND SAFETY VALVES.		

DWG NO. 300B0454

SCALE	CAD/FULL
DATE	2-22-07
DRAWN	JRS
CHECKED	
APPROVED	

JOHNSTON BOILER COMPANY
FERRYSBURG, MICHIGAN 49409

SO#

BOILER TEMPLATE - 509
PFTA250-4-30#W

DWG. NO. 300B0454-01

REV A